

CITY OF SPRINGFIELD
INTER-OFFICE MEMORANDUM

ATTENTION OR MEMO TO FILE _____

DATE April 1, 1977 _____

DEPARTMENT _____

Re: A & A Mann. Co. boiler discharge

On the afternoon of March 24, 1977, Steve Short and myself observed a discharge coming from A & A Manufacturing Co. The discharge flowed from a pipe through the wall at the southwest corner of the building into a short open channel which emptied into the storm sewer directly south of the building. The drain was dyed to verify that it did, in fact, go to the storm sewer since a sanitary sewer main lies parallel to the storm sewer at this point.

It was noted that the discharge was warm: probably around 80° F. Further inspection revealed the discharge was coming from the boiler used in the steam pressing operation.

No action has been taken on this matter at this time.

2000 N. NATIONAL

SIGNED

Gary J. Pendergrass
Gary Pendergrass, WPC1 II, S & E